


WESTERN ELECTRO-ACOUSTIC LABORATORY

Report No. TL10-585



1/3 OCT BND CNTR	FREQ	63	80	100	125	160	200	250	315	400	500
TL in dB		6	8	9	7	7	6	8	10	11	13
95% Confidence in dB deficiencies		1.42	1.92	2.07	1.47	0.89	0.76 (1)	0.80 (2)	0.52 (3)	0.36 (5)	0.38 (4)
1/3 OCT BND CNTR	FREQ	630	800	1000	1250	1600	2000	2500	3150	4000	5000
TL in dB		14	15	17	19	21	22	24	26	27	29
95% Confidence in dB deficiencies		0.29 (4)	0.44 (4)	0.38 (3)	0.39 (2)	0.36 (0)	0.56	0.55	0.31	0.32	0.50

EWR	OITC
18	12

Specimen Area: 23.41 sq.ft.
 Temperature: 78.3 deg. F
 Relative Humidity: 43 %
 Test Date: 30 August 2010

STC
17
(28)